

Brown Hall LEED Scorecard Update

LEED NC 2.1

3/15/2010

| Credit | Projected | Actual | Comments |
|-------------------------------------|------------------|---|--|
| WE 3: Water Use Reduction | | 31% Reduction | Based on low flow plumbing fixtures used |
| -20% Reduction | 0 points | 1 point | |
| -30% Reduction | 0 points | 1 point | |
| MR 2: Construction Waste Management | | 73% Recycled | 1256 tons recycled- concrete, steel, asphalt, drywall and wood (plus Habitat for Humanity salvage) |
| -50% Wastes Recycled | 1 point | 1 point | |
| -75% Wastes Recycled | 0 points | 0 points | |
| MR 4: Recycled Content Materials | | 39% Recycled Content | Innovation credit for exceeding reqmt by more than 100% (Post Consumer + 1/2 Post Industrial) + 1 Innovation point |
| -5% Recycled Content | 1 point | 1 point | |
| -10% Recycled Content | 0 points | 1 point | |
| MR 5: Local/Regional Materials | | 65% Manuf within 500 mi | Innovation credit for exceeding reqmt by more than 100% |
| -20% Manuf within 500 mi | 0 points | one point + 1 Innovation point | |
| -50% Extracted within 500 mi | 0 points | 46% Extracted within 500 mi 0 points | |
| MR 6: Rapidly Renewable Materials | | 3.3% Rapidly Renewable | Cork & Linoleum flooring used (2.5% is threshold in NC 2009) |
| -5% Rapidly Renewable | 0 points | 0 points | |
| Overall Score | 27 Certified | 33 Silver | Certified 26-32 points Silver 33-38 points |

Note: Overall score is tentative. Actual score for other credits such as Energy Performance & Indoor Environmental Quality have not been verified.

